



the Energy to Lead


Integrated CHP Using Ultra-Low-NOx Supplemental Firing

- > ***Final meeting***
- > *California Air Resources Board*
- > *Sacramento, California*


- > May 4, 2010

Gas Technology Institute

Addressing Key Issues for the Energy Industry



- > Contract Research
- > Program Management
- > Technical Services
- > Education and Training



- > Over 1,000 patents
- > Nearly 500 products commercialized

Facilities and Staff

Facilities:

- 18-acre main campus
- 28 specialized laboratories (280,000 ft²)
- Pilot scale gasifier
- Pipe test farm
- 80 acre drilling test facility (OK)
- Offices in Washington DC, Houston, Birmingham



Flex-Fuel Test Facility



Offices and Labs


Staff of 250:

- 70% are scientists and engineers



Energy and Environmental Technology Center

Efforts aligned with the industry value chain



Overview

- ☐ Objectives and Approach
- ☐ Technology Description
- ☐ Lab-Scale Development
- ☐ Scale-up
- ☐ Field Test Site
- ☐ Next Steps

Origin of the Project

Problem

- > Combined heat and power (CHP) systems based on gas turbines save energy and \$\$\$ for gas users, BUT...
 - Exhaust losses are relatively high due to high excess air required for turbine
 - Supplemental burners can reduce the exhaust loss but add more NO_x
 - Current supplemental burners are challenged to meet the 2007 Fossil Fuel Emissions Standard for turbines *0.07 lb NO_x per MWh total output*

There is a Need to Develop . . .

- > Integrated CHP packages that match
 - A power generator (turbine)
 - A low emission supplemental burner
 - A waste heat user (boiler)
- > To improve energy efficiency and meet clean air requirements
- > An advanced burner
 - Very low emissions . . . even with high-temperature turbine exhaust gas (600-1100°F) as an oxidant

Benefits to ARB Program

- > Promotes the development, commercialization, and use of zero- and near-zero emission technologies
- > Helps ARB fulfill its stated mission "to promote and protect public health, welfare and ecological resources through the effective and efficient reduction of air pollutants while recognizing and considering the effects on the economy of the state"

Benefits

- > Enhance market acceptance of CHP
 - Save many \$\$\$ for gas customers
 - Smog mitigation through NOx reduction
 - Widely recognized as a potential means of increasing energy efficiency
 - A cost-effective means of satisfying the steam needs of a wide variety of facilities – an alternative to SCR
- > Californians
 - Lower energy costs through the more efficient use of natural gas
 - Increased security of electricity supply through on site generation
 - Improved environmental quality

Objectives and Approach

Two Objectives

- > Innovative burner development
 - Cultivate promising R&D results
 - Obtain industry support
- > Pre-engineering of a cost-effective CHP package
 - Employ state-of-the-art technology
 - Enlist a strong project team
 - Bring technology to the market

Project Goal and Objectives

> Goal

- Develop a cost-effective gas turbine based CHP system that improves overall efficiency and meets 2007 Fossil Fuel Emissions Standard without catalytic exhaust gas treatment

> Objectives

- Achieve 84% (HHV) system efficiency
- Generate a pre-engineered cost-effective CHP package employing state-of-the-art design concepts
- Validate the system in the GTI laboratory
- Demonstrate the system at a end-user site

Performance Targets

- > Develop a novel supplemental burner for conventional turbines and microturbine-based CHP applications
- > Integrate the burner into a cost-effective CHP package that improves overall efficiency and meets 2007 Fossil Fuel Emissions Standard without SCR
- > Performance goals:
 - 84% HHV system efficiency
 - <0.07 lb/MWh NO_x
 - 4 to 1 turndown

Project Team

> Performing organizations

- Gas Technology Institute
- Integrated CHP Systems Corporation
- Accu Chem Conversion, Incorporated


> Sponsors

- California Air Resources Board
- California Energy Commission
- Utilization Technology Development NF
- Gas Research Institute

Technology Description

Technology . . .


- > Supplemental Ultra-Low-NOx (ULN) burner features
 - Based on forced internal recirculation (FIR) burner combustion method



And Innovation . . .

> Supplemental ULN burner features

- Less than three inches wc burner pressure drop
- Targeted for boilers and absorption chillers
- Significant thermal energy added to the turbine exhaust gas
- No blower required
- No augmentation air requirement



Lab-Scale Development

Supplemental ULN Burner Integrated with Microturbine


- > Advanced burner technology for CHP systems
 - Capstone 60-kW microturbine
 - > 17.8% O₂
 - > 3.4 vppm NO_x
 - > 9 vppm CO
 - > 610°F
 - > 6 in wc
 - Increases CHP efficiency
 - Reduces emissions



ULN Supplemental Burner Technology

> Breakthrough design

- Part of FIR family



FlexCHP-60 Lab Performance


	Microturbine	Microturbine + Supplemental ULN Burner
Turbine Output, kW	50	50
Burner Heat Input, million Btu/h	--	2.11
O₂, vol%	17.8	8.1
NO_x, vppm	3.4	2.2
CO, vppm	9	5
NO_x Reduction, %	--	35.2

- > Reduces NO_x in exhaust
- > Reduces excess air
- > Lab tests show 35 - 48% NO_x reduction compared to raw turbine exhaust

Supplemental Burner for CHP

>Laboratory results

- With unmodified Capstone TEG, NOx reduced 35%
- With NOx doping (46 vppm) to simulate an older turbine, NOx reduced 70%
- CO below 10 vppm in all cases



Scale-up

Scale-Up

> Scale-up issues

- Cost
- Emissions
- Velocities and pressures drops
- Utilization of existing components
- What is common market size?
- What demonstration sites are available?

STEG Generation

- > Investigated various approaches to generate simulated turbine exhaust gas (STEG) in laboratory
 - Up to 20% of a Solar Mercury 50 output

Summary of Mercury 50 Emissions Data				
Turbine Load, %	25	50	75	100
Exhaust Temperature, °F	637	666	681	705
Oxygen Content Dry Based, %	17.8	17.2	16.7	16.4
Carbon Dioxide Dry Based, %	1.8	2.2	2.4	2.6
NOx Content, vppm	--	5	5	5

Supplemental ULN Burner 7.5 million Btu/h Capacity




Supplemental ULN Burner




Auxiliary Burner

Burner Flame



7.06 million Btu/h
STEG NO_x 5.0 vppm
Stack NO_x 2.4 vppm

Supplemental ULN Burner Gas Turbine Load 100%



Field Test Site

Accu Chem Conversion, Inc.




Trans-Loading Facility




Biodiesel Refinery

Representative Electrical Profile



12-Hour Batch

CHP Plant Layout




FlexCHP-65

4 million Btu/h Capacity




FlexCHP-65

3 million Btu/h



Emissions over Firing Rate



Next Steps

Project Plan

- > The project will be completed to its natural conclusion with co funding from other sponsors
 - Complete performance testing based on the Final Laboratory Performance Test Plan
 - Install and evaluate the FlexCHP-65 system at end-user site
 - Technology transfer and commercialization readiness activities



**Creating
technology solutions
with **impact****

▼
**across the
energy spectrum**

For more information:

David Cygan

T: 847-768-0524

david.cygan@gastechnology.org
www.gastechnology.org